

# Westinghouse



67000-  
2400/4160Y/2400XVOLTS  
12470Y/7200

60 HERTZ  
L. SPEC.877216

SERIAL

RPF10871

THREE PHASE  
TYPE SL  
LOAD TAP CHANGING  
**TRANSFORMER**

CLASS OA/FA\*  
INSULOUR INSULATION

FULL LOAD CONTINUOUSLY  
10000/12500 KVA-55°C. RISE\*  
11200/14000 KVA-65°C. RISE

GALLONS OIL  
I.T.C.  
COMPARTMENT 360

TRANS. TANK 4088

INSTRUCTION BOOK RPF10871

FULL WAVE IMPULSE TEST LEVEL: H.V. SERIES 350 KV., L.V. SERIES 110 KV., L.V. PARALLEL 75 KV.

IMPEDANCE 7.8 % AT 10000 KVA, 67000 TO12470Y/7200 VOLTS

IMPEDANCE 8.7 % AT 11200 KVA, 67000 TO12470Y/7200 VOLTS

APPROX. WEIGHT IN LBS. CORE AND COILS 35850 CASE 24700 OIL 33350 TOTAL 93900

MADE IN U.S.A. WESTINGHOUSE ELECTRIC CORPORATION 197 P 564 H01-B

FOR TABLE OF CONNECTIONS AND NOTES SEE INSTRUCTION PLATE 197 P 565 H01

