



# RAINFOOF ENCLOSURE INTERLOCKED ARKTITE® RECEPTACLE WITH ENCLOSED SWITCH

## SUITABLE FOR USE AS SERVICE EQUIPMENT

THIS SWITCH IS SUITABLE FOR USE ON A CIRCUIT CAPABLE OF DELIVERING NOT MORE THAN 10,000 AMPERES RMS SYMMETRICAL NAMEPLATE RATED VOLTS MAXIMUM.

NOT FOR USE WITH CLASS J OR CLASS R FUSES

### DANGER

THIS SWITCH MAY PRESENT A RISK OF FIRE AND PERSONAL INJURY IF INSTALLED ON A CIRCUIT CAPABLE OF DELIVERING MORE THAN 10,000 RMS SYMMETRICAL AMPERES.

WHEN USED AS A TWO POLE SWITCH, USE THE TWO (2) OUTSIDE POLES

THE USE OF RENEWABLE LINK FUSES IN THE SWITCH IS NOT RECOMMENDED

TO BOND ENCLOSURE TO NEUTRAL (WHEN REQUIRED), ASSEMBLE BONDING SCREW PROVIDED WITH NEUTRAL BLOCK IN MOUNTING PLATE BONDING SCREW HOLE.

CONTINUOUS LOAD CURRENT NOT TO EXCEED 80% OF THE RATING OF FUSES EMPLOYED IN OTHER THAN MOTOR CIRCUITS.

THE STARTING CURRENT OF MOTORS OF MORE THAN THE STANDARD HORSEPOWER RATING MAY REQUIRE THE USE OF FUSES WITH APPROPRIATE TIME DELAY CHARACTERISTICS.

ENCLOSURE MUST BE GROUNDED IN ACCORDANCE WITH ARTICLE 250 OF THE NATIONAL ELECTRICAL CODE. WHERE CONDUIT IS USED AS GROUND, USER MUST PROVIDE JUMPER FROM CONDUIT TO GROUND TERMINAL. SEPARATE GROUND LEAD MUST TERMINATE AT GROUND TERMINAL.

MANUFACTURER	TYPE	AMPS	PERMISSIBLE WIRE SIZE/TYPE	WIRE TERMINAL TORQUE (LB. - IN.)
WESTINGHOUSE	DS	30A	#10-2 CU 60°C/75°C	50
NEUTRAL BLOCK			#10-4 CU 75°C	50

USE COPPER WIRE ONLY

COOPER INDUSTRIES INC.  
CROUSE-HINDS DIVISION  
SYRACUSE, NEW YORK 13221 USA

0400223 REV 1

